

**Fire Test Report**  
**API Standard 6FB, Third Edition**

*Performed for*

**Reinz Dichtungs-GmbH**

[www.reinz-industrial.com](http://www.reinz-industrial.com)



**6 inch Class 300 AFM 34 CO ME Gasket**

Project Number: 218134

Test Date: June 19, 2018



*Performed by*

**YARMOUTH RESEARCH AND TECHNOLOGY, LLC**

434 Walnut Hill Road  
North Yarmouth, ME 04097 USA  
(207) 829-5359

[info@yarmouthresearch.com](mailto:info@yarmouthresearch.com)

[www.yarmouthresearch.com](http://www.yarmouthresearch.com)

# Yarmouth Research and Technology, LLC

## API 6FB FIRE TEST REPORT

<b>Customer:</b>	Reinz Dichtungs-GmbH	<b>Date:</b>	6/19/2018
<b>Project Number:</b>	218134		
<b>Product Code:</b>	6 inch Class 300 AFM 34 CO ME Gasket		
<b>Specification:</b>	API 6FB, Third Edition, Nov. 1998 Non-Bending, On-shore Test		
<b>Gasket Thickness:</b>	0.075	inches	
<b>Seal Area OD:</b>	8.500	<b>Seal Area ID:</b>	6.625 inches
<b>Mean Seal Diameter:</b>	7.5625	inches	
<b>Mean Circumference:</b>	23.76	inches	
<b>Allowable Leakage:</b>	23.76	ml/min	
<b>Nominal Test Pressure:</b>	555	psig	
<b>YRT Technician:</b>	Matthew J. Wasielewski, P.E.		
	<b>Version of YRT's FIRE-Control 6FB Software: B</b>		
	<b>Equipment Confirmed to be in Calibration to NIST Standards: Yes</b>		

### *Burn and Cool Down Test*

	Burn Start Time:	9:33:00	
	Burn / Cooldown Duration:	60	minutes
	Average Pressure During Burn/Cooldown:	573	psig
	Leak Rate During Burn/Cool Down:	1.1	ml/min
	Allowable External Leak Rate:	23.76	ml/min
	Amount of Time of Avg. Cal. Block > 1200 deg.:	17.8	minutes
	Were Test Conditions Within Compliance?	Yes	
	Was the Leakage Below the Allowable?	Yes	

### *Depressurization - Repressurization Test*

	Average Pressure During Test:	566	psig
	Gasket Leak Rate:	0	ml/min
	Allowable External Leak Rate:	23.76	ml/min
	Was the Leakage Below the Allowable?	Yes	
	<b>Does the Gasket Pass or Fail API 6FB?</b>	<b>PASS</b>	

*Certified By:*



Matthew J. Wasielewski, PE

President and Manager

Yarmouth Research and Technology, LLC

